

Film Fire/ Life Safety Inspection Checklist

	YES	NO
1. Access		
A. Fire lanes kept clear (20 feet wide)	<input type="checkbox"/>	<input type="checkbox"/>
B. Hydrants not blocked	<input type="checkbox"/>	<input type="checkbox"/>
C. Fire Department Connections Clear	<input type="checkbox"/>	<input type="checkbox"/>
D. Standpipe connections clear	<input type="checkbox"/>	<input type="checkbox"/>
2. Parking		
A. Special Effects trucks parked in designated location	<input type="checkbox"/>	<input type="checkbox"/>
B. Refueler Vehicles parked in designated locations	<input type="checkbox"/>	<input type="checkbox"/>
C. All vehicles parked minimum 20 feet from tents	<input type="checkbox"/>	<input type="checkbox"/>
D. Catering Trucks parked in designated locations	<input type="checkbox"/>	<input type="checkbox"/>
E. Generator truck parked in designated location	<input type="checkbox"/>	<input type="checkbox"/>
F. Water tenders parked in designated locations	<input type="checkbox"/>	<input type="checkbox"/>
G. Dry vegetation cleared from designated parking areas	<input type="checkbox"/>	<input type="checkbox"/>
3. Exiting		
A. All designated exits kept clear	<input type="checkbox"/>	<input type="checkbox"/>
B. Exits visible	<input type="checkbox"/>	<input type="checkbox"/>
C. No flammable liquids, LPG or pyrotechnics near an exit	<input type="checkbox"/>	<input type="checkbox"/>
4. Pyrotechnic Special Effects		
A. Pyrotechnician in possession of proper license	<input type="checkbox"/>	<input type="checkbox"/>
B. Permit on site	<input type="checkbox"/>	<input type="checkbox"/>
C. Fire department briefed on proposed activity	<input type="checkbox"/>	<input type="checkbox"/>
D. Alternative means of protection provided	<input type="checkbox"/>	<input type="checkbox"/>
E. Special Effects in Class II Magazine or Department of Transportation Carton	<input type="checkbox"/>	<input type="checkbox"/>
F. Fire extinguishment provided by pyrotechnician	<input type="checkbox"/>	<input type="checkbox"/>
G. Extinguishment equipment charged and in good working order	<input type="checkbox"/>	<input type="checkbox"/>
5. Flammable Liquids and Gases		
A. Proper storage in approved containers	<input type="checkbox"/>	<input type="checkbox"/>
B. Pressure vessels identified as to contents	<input type="checkbox"/>	<input type="checkbox"/>
C. Pressure vessels secured	<input type="checkbox"/>	<input type="checkbox"/>
D. Approved hoses and valves for pressurised gases	<input type="checkbox"/>	<input type="checkbox"/>



- E. Flammable liquids and gases kept away from heat sources
- F. No refuelling of equipment while in operation
- G. Refuelling done in remote area
- H. Aircraft refuelled in designated site on location
- I. Supply and receiving vessels bonded together
- J. No leakage of fuels from generator
- K. Spray painting and lacquer application performed safely
- L. Proper ventilation to prevent flammable vapours from accumulating

6. Electrical and Lighting

- A. Cords and connections in good condition (no deterioration)
- B. Extension cords not used as substitute for permanent wiring of building
- C. A/C properly grounded
- D. Generators attended to and in good repair
- E. Generators grounded
- F. Cables properly protected, bundled, and kept as clear as possible at exits
- G. Combustible materials kept clear of light fixtures

7. Welding, Cutting and Grinding

- A. Combustible materials within 10 feet of welding relocated or covered
- B. Flammable liquids removed from area where grinding sparks are produced
- C. Fire extinguishers provided on welding set

8. Smoking

- A. Smoking prohibited near pyrotechnic special effects storage, or flammable liquids storage and dispensing area
- B. Designated smoking areas, if any, clearly marked
- C. NO SMOKING signs prominently visible where smoking is prohibited

9. Miscellaneous

- A. Film permit on site
- B. All sprinkler and standpipe systems fully operational
- C. Extinguishers present and ready for use



- D. Methods of reporting an emergency available
- E. Catering trucks provided with fire extinguishers
- F. Light combustibles in carpenter shop and other work areas removed frequently
- G. Tent materials flame retardant
- H. Fabrics, draperies etc. flame retardant
- I. Brush cleared adequately at outdoor filming locations
- J. Open burning in compliance with all regulations
- K. Helistop clearly delineated and adequately cleared
- L. Bleachers and grandstands constructed to withstand loads imposed
- M. Greens (trees, bushes, etc.), if not fresh or live, flame retardant

10. Required Permits and/or Certificates

- A. Film Permit
- B. Special Effects (pyrotechnic or non-pyrotechnic)
- C. Refueler vehicle
- D. Welding and/or cutting
- E. Tent
- F. Flame retardant

